

OFFICE OF THE DY COMMANDANT  
CENTRAL INDUSTRIAL SECURITY FORCE  
(MINISTRY OF HOME AFFAIRS)

CISF UNIT BTPS Bokaro  
Post: Bokaro Thermal (Jh.)  
Dated: 22 /10/2019

No.E-42099/CISF/BTPS/FW/2019- 347

**TO WHOM IT MAY CONCERN**

**CERTIFICATE**

To control the fire in its incipient stage as per BIS-2190, the following First Aid Fire Fighting extinguishers have been installed in the school premises of KV DVC Bokaro Thermal.

SL No	Class	Type	Capacity	Nos
01	A Class Fire	Water Type	09 ltrs	02 Nos
02	B Class Fire	Foam Type	09 Ltrs	01 No
03	C Class Fire	CO <sub>2</sub>	4.5 kg	02 Nos
04	C Class Fire	CO <sub>2</sub>	6.8 kg	01 No

02. CISF Fire prevention team has checked & tested the performance of all above fire equipments & all are operationally worthy to meet the requirements of fire safety.

03. It is certified that CISF Fire prevention team have imparted the training to all staff of KV for handling the First Aid Fire Fighting appliances during any fire emergency & all staff of KV are well conversant about operating procedure of the portable fire extinguishers.

This certificate has been issued on the request of KV Principal vide office letter No. F: 4029/1-3/1154/DVC/2019-20 dated 22-10-2019.

  
ASSTT. COMMANDANT/FIRE  
CISF UNIT BTPS BOKARO

To,  
The Principal  
KV DVC Bokaro Thermal

Copy to:-

The Dy. Commandant  
CISF Unit BTPS Bokaro

: for kind information please.